NOTICE ABOUT YOUR DRINKING WATER

Treatment Requirements Not Met

Public Water System Name:Andover Village District PWS ID:0081010			
We routinely monitor your water for turbidity. Turbidity is a measure of the cloudiness of the water. This measurement shows if the water supply is effectively being filtered. If the turbidity level is too high, organisms could grow in the water system.			
The maximum turbidity level allowed was exceeded on:			
Date(s)	Turbidity Level (in NTU)	Maximum Turbidity Level Allowed (in NTU)	Our Normal Turbidity Level (in NTU)
7-26,27th and 28th	Low CI levels	4.0	1.3
What should I do? This is not an emergency. If it had been, you would have been notified immediately. Monitoring results during this time period did / did not indicate the presence of bacteria in the water. (circle one)			
Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.			
It is not necessary to use alternate water; however, if you have specific health concerns, please contact your health care professional. General health-related questions may be directed to the EPA Safe Drinking Water Hotline at 1-800-426-4791.			
Steps being taken to correct the situation:Line was repaired and facility cleaned up			
Expected Resolution Date:7/29/2024			
Contact Name: John Coffey Company: Andover Village District			
Address: P. Box 185 Canaan N.H. 03741Telephone Number:603-304-9380			
Please share this information with all the other people who drink this water, especially those who may not			

have received this notice directly (for example; people in apartments, nursing homes, schools and businesses).

You can do this by posting this notice in a public place or distributing copies by hand or mail.